
ELECTRICAL DESIGN CONSULTANTS

2527 Junction Drive · Rapid City, South Dakota 57702 · (605)-341-1250

ELECTRICAL ADDENDUM #1

DATE: MARCH 18, 2010

SUBJECT: CROOK COUNTY COURTHOUSE GENERATORS
SUNDANCE, WYOMING

FILE: GILL2.DOC

This Addendum is issued to revise and clarify the original bid documents for the Crook County Courthouse and Public Health Building project, Sundance, Wyoming, and shall be considered as part of those documents hence forth.

Electrical items

1. Owner will remove existing generator and shed.
2. Contractor is to remove existing concrete, including the sidewalk, apron, and generator pad complete.
3. Contractor to replace all sidewalks and apron. Contractor to provide concrete expansion joints between new generator pad and sidewalks and apron at the Courthouse. Contractor to provide both concrete generator pads, based on Owner provided generator sets at the Courthouse and the Public Health building.
4. Owner will provide equipment to set both generators on the concrete pads.

END OF ELECTRICAL ADDENDUM #1

DOUGLAS E. VALLIS, P.E.
Senior Electrical Engineer

Note: Bids must be submitted to the Public Works Office on or before Tuesday, April 6th at 5 PM .